

Electrical Signaling

Electrical protective signaling systems are configurations of components used to produce alarm signals indicative of fire, smoke, sprinkler waterflow or other emergency and to produce supervisory signals indicative of conditions needing attention with respect to protection equipment or watch service. System configurations are classified according to where and how the signals are received. The categories are commonly designated as local, municipal, remote station, proprietary, emergency voice/alarm communication, emergency communication, and central station. Auxiliary systems are either local or proprietary systems interconnected with a municipal system.

This category presents the major system component categories and the integrated system configurations. The selection of components to form a hybrid system should be made only by those skilled in system design. Also, the suitability of any system application should be judged on the basis of the hazard(s) being protected.

Alarm Signal Initiating Devices

Alarm signals are initiated either automatically or manually. Automatic detectors respond to changes in characteristic phenomena associated with fire or other emergency conditions.

Fire Detection, Heat-Actuated

Heat sensitive devices may be either "spot" or "line" type and operate at a fixed temperature or on a rapid increase in temperature (rate-of-rise). Some detectors combine the fixed and rate sensitive principles.

The spacing guides listed are indicative of each detector's relative sensitivity and, in each case, the spacing guide is the maximum recommended separation between detectors for smooth-ceiling installations. For a given temperature rating, a fixed-temperature detector which has a 30 ft (9 m) listing and one which has a 15 ft (5 m) listing will both respond at approximately the same time to a geometrically growing fire if each is installed at its listed spacing. FM Approved rate-of-rise detectors all have 30 ft (9 m) listed spacings, the maximum separation recommended by FM Approvals.

Installation of heat detectors at less than maximum spacing is necessary: to achieve earlier response; to compensate for ceiling obstructions such as beams and joists; and to compensate for ceiling heights greater than 15 ft (5 m). Proper location and use of heat detectors involves consideration of ceiling construction, the location of partitions, the maximum normal room temperature, heat produced by the occupancy, and whether detector function is to warn occupants or to automatically actuate protection equipment. Refer to Standard 72-1993 of the National Fire Protection Association and design specifications published by jurisdictional authorities, as appropriate.

Model ACD-V Smoke and Heat Multi-Sensor Detector

Compatible fire alarm panels	FireNET Plus series, 1 loop, 2 loop fire alarm control panels;
Maximum number of devices per SLC loop	127 devices
Compatible detector bases	ASBL, YBN-NSA-4, HSB-NSA-6, ASB, SCI-B4 and SCI-B6
Fixed temperature operating range	57°C, Rate Compensated
Rate of Rise feature	Yes
RTI classification	Quick
Maximum spacing	6m by 6m (20ft by 20ft) – if installed as a heat detector
Operating voltage range	17 to 41Vdc
Operating temperature range	-10° to 50°C;
Air velocity range	0-4000 fpm
Maximum humidity	0 to 95% RH, non-condensing
Power consumption	Standby : 450µA; Alarm: 7.2mA;
Outputs	Multi-color LED, relay with R2M modules
Transmission method	Digital Communication Protocol (DCP)
Enclosure	Indoor use only;

Company Name:	Hochiki America Corp
Company Address:	7051 Village Dr, Suite 100, Buena Park, California 90621, USA

Company Website:	http://hochiki.com
New/Updated Product Listing:	Yes
Listing Country:	United States of America
Certificate Number:	
Certification Type:	FM Approved