

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0119

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models AL-DFE-135 and AL-DFE-190. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, temperature & electrical ratings and UL label.

APPROVAL: Listed as system heat detectors when used in conjunction with listed compatible bases (CSFM Listing No. 7300-0410:132) and separately listed compatible control units.

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0107

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models SLG-12, SLG-24, SLG-24FH, SLG-24F, SLK-12, SLK-24F, SLK-24FH, SLK-24FB, SLK-24FL, SLK-24FLB, SLK-835, SLK-835H, SLR-835, SLR-835W, SLR-835B-2, SLR-835B-4, SLR-835B-2W, SLR-835B-4W, SLR-24, SLR-24H, SLR-24V, *SLR-24VN, SLR-835H, SLR-835HW, SLR-835BH-2, SLR-835BH-2W, SLR-835BH-4, SLR-835BH-4W photoelectric type smoke detectors. Unit with suffix -H or -FH employs a supplemental heat sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 VDC and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with separately listed compatible fire alarm control units when used in conjunction with listee's listed bases (CSFM Listing No. 7300-0410:132). Models with supplemental heat sensor are not approved for use in lieu of required heat detectors.

NOTE: Formerly 7257-0410:107

*Rev 2-14-2003 IPI



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM**



LISTING SERVICE

LISTING No. 7300-0410:0132

Page 1 of 2

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Detector bases (2 and 4-wire). Unit is intended for use with a separately listed compatible detector head. Refer to listee's data sheet for detailed product description and operational considerations. Models listed below.

| | | | |
|-----------|-----------|-----------|------------|
| HA-4W | HA-4W1 | HA-4WX | HA-2 |
| HA-SL | HA-SR | HA-SLR | HA-RA2 |
| HA-NRA2 | HA-L12R | HA-2R | HA-22R |
| HA-L2 | HA-L2A | HA-L2R | HA-L22 |
| HA-L22A | HA-L22F | HA-L22R | HA-L22S |
| HA-LA2 | HA-LRA | HA-LRA2 | HA-LNA2 |
| HA-LNRA2 | | | |
| | | | |
| HS-2 | HS-2L | HS-2D | HS-21 |
| HS-21L | HS-21D | HS-22 | HS-22L |
| HS-22D | HS-100 | HS-200D | HS-220 |
| HS-220L | HS-220D | HS-221 | HS-221L |
| HS-221D | HS-221X | HS-221XL | HS-221XD |
| HS-224 | HS-224L | HS-224D | HS-225 |
| HS-225L | HS-225D | HS-2RB | HS-21RB |
| HS-220RB | HS-221RB | HS-224RB | HS-2RB4 |
| | | | |
| HSB-2 | HSB-2N | HSB-12-1 | HSB-12-1N |
| HSB-12-4 | HSB-12-4N | HSB-21 | HSB-21N |
| HSB-100 | HSB-200 | HSB-200N | HSB-220 |
| HSB-220N | HSB-221 | HSB-221N | HSB-221S |
| HSB-224 | HSB-224N | HSB-225 | HSB-225N |
| HSC-4R | HSC-21L | HSC-220L | HSC-220R |
| HSC-221L | HSC-221R | HSC-224RA | HSC-224L |
| HSC-224R | HSC-225L | HSB-DCP-6 | HSB-NSA-6 |
| *HSC-4R12 | | | |
| | | | |
| YBA-M2 | YBA-M21 | YBA-M22 | YBA-M220 |
| YBA-M221 | YBA-M224 | YBA-M225 | YBA-M100 |
| YBA-MAP | YBA-R3 | YBA-RL/4 | YBA-RL/4-1 |

*Revision 7-20-22 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

| | | | |
|-------------|-------------|-------------|-------------|
| YBA-RL/4-2 | YBA-RL/4-RA | YBC-RL/12 | YBC-RL/12-1 |
| YBC-RL/12-2 | YBC-RL/12-4 | YBC-RL/4-RA | YBC-RL/2NC |
| YBC-RL/2NBE | YBJ-RL/2ND | YBN-R/2NA | YBN-NSA-4 |
| NS4-100 | NS4-220 | NS4-221 | NS4-224 |
| NS6-100 | NS6-220 | NS6-221 | NS6-224 |
| FFO-4BASE | FFO-6BASE | FFO-SBASE | |

Models may or may not come with suffix -W.

- RATING:** *Refer to the detector base's data sheet.
- INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
- MARKING:** Listee's name, model number, electrical rating, and UL label.
- APPROVAL:** Listed as bases for use with listee's separately listed compatible smoke and heat detectors. Refer to heat or smoke detector listings for compatibility. Models HA-2R, HA-SLR, HA-LRA2 and HSC Series w/ suffix R are also suitable for releasing device service. Model YBA-R3 is intended for use with thermostat detector only. *Models HSC-220R, HSC-221R, HSC-224R, HSC-4R, and HSC-4R12 complies with the applicable requirements in UL 268, 7th Edition.
- NOTE:** Formerly 7300-0410:0100, 0106, 0115, 0124, 0125, 0126, 0130, 0131 & 0133

*Revision 7-20-22 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0147

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models ATG - EA and FFO-HEAT electronic fixed temperature heat detector (analog) with Models YBN-NSA-4, HSB-NSA-6, FFO-4BASE or FFO-6BASE bases. Unit consists of resistors, capacitors, diodes, transistors, LED, thermistors, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 39.5 VDC
Temperature Range: 134°F - 149°F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical/temperature rating and UL label.

APPROVAL: Listed as heat detector for use with separately listed compatible fire alarm control units.

Rev 08-13-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0149 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models ALG-EA and ALG-V analog addressable photoelectric type smoke detector with Models YBN-NSA-4 and HSB-NSA-6 bases. Unit consists of resistors, capacitors, diodes, transistors, LED, photo diode, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 39.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector for use with separately listed compatible fire alarm control units. *Model ALG-V is suitable for in duct use in air velocities up to 4000 ft/min.

NOTE:

*Rev 1-31-2008 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0150

Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Control Unit Accessories Models:

DCP-RM, DCP-R2M, FFO-2RM; Analog Relay Module
DCP-SCI, FFO-SCIM; Short Circuit Isolator
DCP-FRCME, DCP-FRCME-M, DCP-FRCME-P, *DCP-FRCME-PI, FFO-MMP; Monitor Modules
DCP-FRCME-S, DCP-FRCME-4, FFO-MM4; Monitor Modules
DCP-FRCME-S-100, DCP-FRCME-4-100; Monitor Modules
DCP-SOM, FFO-OM; Supervised Output Module
DCP-SRM; Solenoid Releasing Module
DCP-DIMM, FFO-2MM; Dual Input Monitor Module
DCP-CZM, FFO-ZM; Conventional Zone Module
DCP-SOM-A; Supervised Output Module
DCP-SOM-R; Supervised Output Module Release
DCP-SOM-AI; Supervised Output Module with Integrated SCI
DCP-FRCMA; Input Module Box Mount
DCP-FRCMA-I; Input Module Box Mount with Integrated SCI
DCP-R2MH; Dual Relay Module, 2 amps @ 30VDC
DCP-R2MH-I; Dual Relay Module, 2 amps @ 30VDC with Integrated SCI
DCP-R2ML; Dual Relay Module, 8 amps @ 30VDC
DCP-R2ML-I; Dual Relay Module, 8 amps @ 30VDC with Integrated SCI
*DCP-CLIM-1, *DCP-CLIM-2 Current Loop Input Modules
SOM-R-DS Key switch Disable Module

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

*03-06-2018 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0151

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models DCD-135 and DCD-190, fixed temperature and rate of rise heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Temperature: DCD-135: 135 F
DCD-190: 190 F

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, rating and UL label.

APPROVAL: Listed as fixed temperature and rate of rise heat detector for use listed bases (CSFM Listing No. 7300-0410:132) and separately listed fire alarm control units.

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0153 Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HRAM-208 remote multiplex annunciator and HRTI-1 Remote trouble Indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-19 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model HCP-200 Series fire alarm control unit (CSFM Listing No. 7165-0410:152).

XLf: 7120-1477:0108

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0154

Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: HCP-1000 fire alarm control unit. Non-coded, automatic, manual, local, auxiliary, remote station, waterflow and sprinkler supervisory service. System components:

| | |
|--------------------|--------------------------------|
| HCP-1000 | Control Unit |
| HBB-1024, HBB-1072 | Backbox |
| HMCC-1024-6, -12 | 24-Zone Chassis |
| HMCC-1024-6S, -12S | 24-Zone Chassis |
| HECH-1048 | Expander Chassis |
| HDM-1008 | 8-Zone Detection Module |
| HSGM-1004 | 4-Zone NAC Module |
| HRM-1008 | Relay Adder Module |
| HPR-100 | Polarity Reversal and City Tie |
| HFA-1024TR | Flush Trim Ring |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Manual for details.

This control unit meets the requirement of UL-864, 8th Edition Standard.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-1477:0106

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3240-0410:0155 Page 1 of 1

CATEGORY: 3240 -- DUCT SMOKE DETECTOR HOUSING/BASE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models DH-98-I, DH-98-P, DH-98-A, DH-98-ARSK, DH-98-ASK, DH-98-AR, DH-98-HVI, DH-98-HVP, DH-99-A duct smoke detectors with ALK-D in duct housing, DH-99-AR duct smoke detector with ALK-D in duct housing, *DH-100-P duct smoke detector with SOC-24DH in duct housing, FFO-DUCT duct smoke detector with FFO-DH in duct housing, and FFO-DUCTR duct smoke detector with FFO-DH in duct housing, duct smoke detector units. Each unit consists of a smoke detector head, plastic enclosure, plastic cover, relays, electrical components, and sampling and exhaust tubes. The smoke detector heads are not suitable for use as open area detection. Refer to listee's data sheet for additional, detailed product description and operational considerations. For use with the following accessories: MS-RA, MS-RA/P, MS-RA/R, MS-RA/P/R, MS-KA/R, MS-KA/P/R, SD505-DTS-K, and MS-RH/KA/P/R remote alarms.

RATING: 120 VAC, 230 VAC, 24 VAC, and 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, and UL label.

APPROVAL: Listed as duct smoke detector units for use with separately listed compatible fire alarm control units to detect an abnormal amount of smoke density in the supply air ducts of air conditioning and ventilating systems. The air velocity in the duct shall be between 300-4000 fpm. *For Model DH-100-P, the air velocity in the duct shall be between 1000-4000 fpm.

NOTE: For duct application only. Not suitable for open area protection.

*Revision 5-10-21 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0157

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HRA-1000 remote multiplex annunciator panel. The main annunciator module provides indication for 32 zones. Each adder annunciator module provides indication for 48 additional zones. Unit includes main annunciator chassis HRAM-1032 and adder annunciator chassis HRAX-1048. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20-29 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For indoor use only.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model HPC-1000 fire alarm control unit (CSFM Listing No. 7165-0410:154).

XLF: 7120-1477:0107

*Rev 11-16-2000



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7260-0410:0158 Page 1 of 1

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model SRA-24 projected beam smoke detector. Unit consists of a transmitter/receiver unit and a reflector unit. This device is intended for ceiling installation only between 25 to 100 ft apart. Refer to the listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical ratings, and UL Label.

APPROVAL: Listed as beam smoke detector for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

4-14-03 KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0159

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model FireNet 4127 Analog Addressable fire alarm control unit. Automatic, manual, waterflow and sprinkler supervisory service. Refer to the listee's data sheet for detailed product description and operational considerations. System components:

| <u>MODULE</u> | <u>PART NO.</u> | <u>DESCRIPTION</u> |
|----------------|-----------------|---|
| FN-4127-BO | (K6002) | Control Board |
| FN-4127-IO | (K6006) | 16 Channel Input/Output Board |
| FN-4127-CPA-BO | (K6001) | Front LCD Indicator Panel |
| FN-4127-SLC | (K6004) | Loop 3, 4 Board |
| FN-4127-NIC | (K6005) | Network Card |
| FN-PS402 | (S402) | Power Supply |
| FN-DAC | (FN-DAC) | Digital Alarm Communicator |
| FN-ENC | (FN-ENC) | Enclosures |
| FN-ACC | (FN-ACC) | Battery/Accessory Enclosure |
| FN-CTM | (7000-00780) | City Tie Module |
| D9068 | (D9068) | Bosch Digital Alarm Communication Transmitter |
| HMX-DP | | Voice Evacuation System Distribution Panel |
| HMX-MP | | Voice Evacuation System Master Panel |
| EVX-100 | | Audio Adjunct Module |
| EVX-RM | | Remote Microphone |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. *Also suitable for high-rise applications.

These control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal as required per NFPA 72, 2002 Edition.

This control unit meets the requirements of UL-864, *9th Edition Standard

NOTE: 1. For Fire Alarm Verification Feature (Delay of fire alarm), the maximum

*Rev 6-24-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

Retard/Reset/Restart period must be adjusted to 30 seconds or less.

2. Combined with 7170-0410:170

*Rev 6-24-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0161 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model ASB detector sounder base. Unit has an integral audible signal for use with spot-type detector units. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a detector base for use with separately listed functionally and electrically compatible fire alarm control units. Designed specifically for use with listee's Model ALG-V (CSFM Listing No. 7272-0410:149) Photoelectric Smoke Detector; Model AIE-EA (CSFM Listing No. 7271-0410:148) Ionization Smoke Detector; Model ATG-EA (CSFM Listing No. 7270-0410:147) Heat Detector; and *Model ACD-V (CSFM Listing No. 7275-0410:0503) combination smoke/heat/CO detector. Refer to listee's Installation Instruction Manual for details.

NOTE: These appliances can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition.

*Revision 05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0410:0162

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HPS-SAH, HPS/SAK, HPS-DAH, HPS-DAH/S, HPS-SAH-WP, *HPS-DAK-SR with or without the suffix DA-C non-coded manual pull stations. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions and applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible fire alarm control units. Model HPS-SAH-WP is suitable for outdoor use. Refer to listee's Installation Instruction Manual for details.

* These manual pull boxes do not meet the requirements of UL Standard 38, 1999 Edition and California amendments.

XLF: 7150-1039:0101

*Revision7-20-2016 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7151-0410:0163

Page 1 of 1

CATEGORY: 7151 -- BOXES/PULL STATIONS-HAZARDOUS LOCATIONS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HPS-SA-EX/WP with or without the suffix DA-C non-coded, explosion proof, weather proof manual pull stations. These devices consist of a switch and terminal block mounted within an explosion proof enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 120 VAC, 10 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm manual pull stations for use with separately listed compatible fire alarm control units. Suitable for use outdoor and in Class I, Group B, C and D; Class II, Group E, F and G hazardous locations. Refer to listee's Installation Instruction Manual for details.

*These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition with California amendments except for models with suffixes -DAH.

XLf: 7151-1039:0104

*Updated 08-27-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0410:0164

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HPS-CP and HPS/CP/S non-coded boxes. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model name, and UL label.

APPROVAL: Listed as fire alarm pull boxes for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

* These manual pull boxes do not meet the requirements of UL Standard 38, 1999 Edition and California amendments.

XLF: 7150-0512:0006

*Updated 6-22-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0165

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model *FN-LCD-N Network LCD Annunciator and **Model FN-LCD-S Serial LCD Annunciator. Connects to the control panel via the RS-485 network interface. Employs four Form C relays that are unsupervised. **Up to 16 FN-LCD-S Serial LCD Annunciators can be connected to one control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model FireNet 4127 fire alarm control unit (CSFM Listing No. 7165-0410:159). Refer to listee's Installation Instruction Manual for details.

*Recert 4-12-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-0410:0166

CATEGORY: 7315 -- POWER UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models FN-642-ULADA, FN-842-ULADA and FN-1042-ULADA Indicating Circuit Power Supply may be followed by -R, -G, -C, or -B. Units are a regulated 12 or 24 VDC power supply/charger used for supervision and expanded power driving capability of four notification appliance circuits. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 VAC primary, 12 or 24 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

NOTE: The system must have the secondary power supply capable of operating the system for at least 24 hours battery standby) in the normal condition and followed by not less than 5 minutes of alarm as required by code. The battery circuit must be fully supervised.

XLF: 7315-1335:0109

5-3-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7315-0410:0168 Page 1 of 1

CATEGORY: 7315 -- POWER UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models FN-600ULX-G, -R, -C, -B Power Supply Units. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 VAC input, 12 or 24 VDC output

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units. Also suitable for use with access control systems. Authority having jurisdiction should be consulted prior to installation.

NOTE: For fire alarm use, the standby batteries must provide at least 24 hours standby power during power loss. The battery circuit must be fully supervised.

XLF: 7315-1335:0104

5-3-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7150-0410:0169

Page 1 of 1

CATEGORY: 7150 -- FIRE ALARM PULL BOXES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models DCP-AMS, DCP-AMS-LP, DCP-AMS-KL, DCP-AMS-KL-LP, *FF0-PULL-SH, *FF0-PULL-SK, *FF0-PULL-DH, and *FF0-PULL-DK addressable fire alarm manual pull boxes. "LP", "DH" and "DK" suffixes are dual action boxes. "KL", "SK", and "DK" suffixes are key lock access boxes. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 33 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as fire alarm manual pull boxes for use with separately listed electrically and functionally compatible fire alarm control units.

These manual pull boxes meet the requirements of UL Standard 38, 1999 Edition and California amendments except models with "LP", "DH", and "DK" suffixes.

*Rev 01-12-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7260-0410:0172

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model SPC-24 Projected Beam, Smoke-Automatic Fire Detector. Unit consists of one emitter unit and one receiver unit. Refer to listee's printed data sheet for additional product description and operational consideration.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL Label

APPROVAL: Listed as beam smoke detectors for use with separately listed compatible fire alarm control units.

NOTE:



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0173

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models ALK-V, ALK-V2,*FFO-SMOKE analog addressable photoelectric type smoke detector with listed compatible bases, Hochiki Model YBN-NSA-4, HSB-NSA-6, *FFO-4BASE or *FFO-6BASE (CSFM Listing No. 7300-0410:0132). Unit consists of resistors, capacitors, diodes, transistors, LED, photo diode, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 39.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as photoelectric smoke detector for use with separately listed compatible fire alarm control units. Also suitable for in-duct use in air velocities up to 4000 ft/min. Refer to listee's Installation Instruction Manual for details.

*Rev 01-12-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0174 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models SLV-24, SLV-24V, SLV-24N and SLV-24M* Conventional, Photoelectric Type Smoke Detectors. Detectors are for use with listed Models NS4-220, NS4-224, NS6-220, NS6-224, HSC-4R, HSC-220R, and HSC-224R Bases. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use with listed bases as shown in "DESIGN" and compatible listed fire alarm control units.

3-19-2008



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0410:0175 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models FNV-MP and FNV-DP audio adjunct/voice evacuation systems. The FNV-MP is the master panel in the system while the FNV-DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

- FNV-PWR2A: Power Supply
- FNV-MFP: Master Fire Phone Card
- FNV-DCC : Data Communication Control Card
- FNV-ASC : Audio System Control Card
- FNV-SSC : Switch Scan Card
- FNV-MMC : Microphone Master Control Card
- FNV-IOI : Input/Output Card
- FNV-SLC : Switch and LED Card
- FNV-MFH : Master Fire Phone Handset Card
- FNV-MBR :Motherboard Card
- FNV-AMI : Audio Module Interface Card
- FNV-FPI : Motherboard/Relay Card
- FNV-25E, -50E or -100E : Audio Adjunct Systems*

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use with separately listed electrically compatible fire alarm control unit. Suitable for high rise applications when used in conjunction with separately listed electrically compatible high rise fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 6911-1446:0103

*Corrected 03-14-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0410:0176 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models EVAX 25, -25E, -50, -50E, -100, -100E, -150, -150E, -200, -200E audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 24-32 VAC/DC, Standby: 24 VDC, 7 Ah Battery

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 6912-1446:0100

8-28-2008 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6912-0410:0177 Page 1 of 1

CATEGORY: 6912 -- VOICE COMMUNICATION ACCESSORIES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model EVX-4Z and EVX-2ZA zone splitters. The unit is intended to be used in conjunction with a listee's separately listed Model EVAX-25 audio adjunct system (CSFM Listing No. 6911-0410:176). Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Input: 24-28 VDC

INSTALLATION: In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a voice communication/audio adjunct system accessories.

XLF: 6912-1446:0101

8-28-2008 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0178

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models DSC-EA Rate-of-rise heat detector. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detector when used in conjunction with listed compatible HSB-100 base (CSFM Listing No. 7300-0410:132) and separately listed compatible control units.

12-15-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3242-0410:0179

Page 1 of 1

CATEGORY: 3242 -- DUCT SMOKE DETECTOR, PHOTO. (W/ OR W/O BASE)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model ALK-D duct smoke detector, analog, addressable photoelectric type sensor. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: The unit is intended to be installed to and mounted in air ducts with airflows up to 4000 ft/min. In accordance with listee's printed installation instructions and applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as photoelectric type, duct smoke detectors for use with separately listed compatible fire alarm control unit, Hochiki Model FireNet 4127 (CSFM Listing No. 7165-0410:159). The unit is for use with listed compatible bases, Hochiki Model YBN-NSA-4 or HSB-NSA-6 (CSFM Listing No. 7300-0410:132). Suitable for use in ducts with airflows up to 4000 ft/min. Refer to listee's Installation Instruction Manual for details.

12-16-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0180

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models FIRENET PLUS 1127 Series. Analog Addressable Fire Alarm System. May be followed by two suffixes R and G which represents the cabinet color of the panel enclosure, R= Red, G= Gray and S, D or L which represents the cabinet style S= Standard, D= Plexi-Window and L= Limited aperture. Non-coded, automatic, manual, local, remote station, central station is with (DACT), waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations and system components:

FPN-n127US00RS; n=(1 or 2) Loop Not Expandable, Red, Standard
FPN-n127US00GS; n=(1 or 2) Loop Not Expandable, Gray, Standard
FPN-n127US20RS; n=(1 or 2) Loop W/Integrated Dialer, Not Expandable, Red, Standard
FPN-n127US20RS; n=(1 or 2) Loop W/Integrated Dialer, Not Expandable, Gray, Standard
FPN-n127US0ERS; n=(1 or 2) Loop Expandable, Red, Standard
FPN-n127US0EGS; n=(1 or 2) Loop Expandable, Gray, Standard
FPN-n127US2ERS; n=(1 or 2) Loop W/Integrated Dialer, Expandable, Red, Standard
FPN-n127US2EGS; n=(1 or 2) Loop W/Integrated Dialer, Expandable, Gray Standard
FPN-1127-SLC; Loop Expansion Module

RATING: 120V, 50 / 60Hz, 2.1A, and 240V, 50 / 60Hz, 1.1A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as fire alarm control units for use with listed compatible indicating and initiating devices.

These control units generate a distinctive temporal pattern (Temporal Pattern Fire Alarm Evacuation) for total evacuation in accordance with NFPA 72, 2002 Edition. This control unit meets the requirements of UL Standard 864, 9th Edition.

These control units generate a distinctive temporal pattern (Temporal Pattern Fire Alarm Evacuation) for total evacuation in accordance with NFPA 72, 2002 Edition. This control unit meets the requirements of UL Standard 864, 9th Edition.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

10/14/2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-2298:0504

10/14/2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0181

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model FNP-LED Graphix LED eMatrix Mimic Display, where X can be the number 1 or 2 denotes color of the enclosure, and -YYY denotes the number of LED extension boards which could be 1, 3 or 5 boards.

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as annunciators for use with listee's separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.

03-01-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0182

Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model ACA-V multi-sensor (photoelectric/heat) type detector. This model employs a 135°F -150°F integral heat sensor. A fire alarm condition may be generated by the presence of smoke or heat. Sensor may operate in a single (heat or photoelectric) or multi mode (heat & photoelectric). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 - 41 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as photoelectric type smoke detector for use with listee's separately listed compatible base and fire alarm control units. Also acceptable for duct application with air velocities from 0-4000 ft/min. Listed as heat type detector for use with listee's separately listed compatible base and fire alarm control units. Listed temperature range for the heat portion is 135°F - 150°F. Refer in Manufacturer's Installation Instruction Manual for details.

08-12-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0183 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HCA-2, HCA-4, HCA-8 fire alarm control units. "*"D" suffix to models adds off-premises signaling utilizing a DACT. Non-coded; automatic, manual, local, remote station, central station, waterflow and sprinkler supervisory service. System components:

HCA-2, -4, -8; Main Fire Alarm Assembly
P/N 06.005, 06.006; End of Line Resistor
P/N 06.007; End of Line Monitor
MBC; Mini Battery Cabinet
HCA-RA; Remote Annunciator
131-035; Actuator
0300-1000; Abort Switch

RATING: 120/240VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and ETL label.

APPROVAL: Listed as fire alarm control units for use with separately listed electrically and functionally compatible initiating and indicating devices.

NOTE: For Fire Alarm Verification Feature, the maximum Retard/Reset/Restart period shall not exceed 30.0 seconds.

*Rev 03-29-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0186 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models SCI-B4 and SCI-B6 Detector Isolator Bases. These models are to be used with listee's Models ACA-V, ALG-V, ALK-V, AIE-EA, and ATG-EA detector heads. The Model SCI-B6 is similar to Model SCI-B4 except for base size, 6 " base versus 4" base.

RATING: 17 - 41 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed for use as detector bases with Manufacturer's Models ACA-V, ALG-V, ALK-V, AIE-EA, ATG-EA, and *ACD-V detector heads. Refer to manufacturer's installation instruction and manual for details.

*Revision 05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0410:0187

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HEH24-WR, HEH24-WW horns and HCC24CR, HCC24CW, HCC24PCR, HCC24PCW, HEC24-15/75WR, HEC24-15/75WW, HEC24-15/75PWR, HEC24-15/75PWW, HEC24-177WR, HEC24-177WW, HEC3-24WR, HEC3-24WW, HEC3-24PWR, HEC3-24PWW, WHEC24-75WR, WHEC24-75WW horn strobes. Suffix W indicating wall, -W or -R indicating color white or red and -P indicating plain. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 24 VDC

Candela: 15cd, 15/75cd, 30cd, 60cd, 75cd, 110cd or 177cd.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horns and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only.

The audible in Models HEH24, HEC24, HEC3-24 may produce distinctive tones including: mechanical, 2400Hz and chime tones in continuous and temporal 3 settings as well as a whoop tone in either a high or low dBA setting.

XLF: 7135-0569:0122

08-02-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0410:0188 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HES24-1575WR, HES24-1575WW, HES24-177WR, HES24-177WW, HES3-24WR, HES3-24WW, HES3-24PWR, HES3-24PWW strobe lights; Models HCS24CR, HCS24CW, HCS24PCR, HCS24PCW strobe lights (synchronization type) and Models HAVSM-R, HAVSM-W Sync Modules. Intended for indoor use and wall mount only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Candela: 15cd, 15cd & 75cd at 00 angle axis
30cd, 60cd, 75cd, 110cd, 177cd.
Model HCS24: Selectable 15cd, 30cd, 75cd, 95cd and 115cd
Model HES3-24: Selectable 15cd, 30cd, 60cd, 75cd and 110cd
Electrical: 21-30 VDC
HAVSM: 8-33 VDC/VFWR
Flash Rate: 60 flashes per minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units.

XLF: 7125-0569:0123

08-03-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0189 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HGOE-R and HGOE-W enclosures. For indoor use only. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a back box and enclosure for use with separately listed audible and visual appliances.

XLF: 7300-0569:0124

08-05-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7135-0410:0190

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HX91-R, HX91-W, HX93-R and HX93-W horns. Model HX-93 has selectable continuous or temporal tones. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 8-33 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horns for use with separately listed compatible fire alarm control units. For indoor use only.

Unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation).

XLF: 7135-0569:0126

08-05-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7125-0410:0192

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HES3-12WR, HES3-12WW, HES3-12PWR and HES3-12PWW strobe lights. Refer to listee's data sheet for additional detailed product description and operational considerations

RATING: Candela: Selectable 15cd, 30cd, 60cd, 75cd
Electrical: 8-17.5 V dc (NOTE: this unit only runs on filtered DC voltage, not on FWR voltage)

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7125-0569:0129

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0410:0193

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HEC3-12 WR, HEC3-12WW, HEC3-12PWR and HEC3-12PWW multi-candela horn/strobes. Model HEC3-12 horn/strobe is wall mounted and for indoor use. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 8-17.5 Vdc, 7-55 mA
Candela: 15cd, 30cd, 60cd, 75cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as horn and horn/strobes for use with separately listed compatible fire alarm control units. For indoor use only. Refer to listee's Installation Instruction Manual for details.

XLF: 7135-0569:0130

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7320-0410:0194

Page 1 of 1

CATEGORY: 7320 -- SPEAKERS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HSSPKCLPR, HSSPKCLPW speakers and Models HSSPK24CLPPR, HSSPK24CLPPW, HSSPK24CLPR and HSSPK24CLPW speaker strobes. Models HSSPKCLPR, HSSPKCLPW are intended for ceiling and wall mount. Other models are ceiling mounted only. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

| | |
|------------|-----------------------------|
| Speaker | 25 Vrms and 70.7 Vrms |
| Strobe | 21-30 VDC |
| Flash Rate | 60 flashes per minute |
| Candela | 15, 30, 60, 75 & 15/75, 110 |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All models are intended for indoor use only and are mounted in a listed double-gang backbox.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Models HSSPK24CLPPR, HSSPK24CLPPW, HSSPK24CLPR and HSSPK24CLPW speaker strobes are suitable for the hearing impaired applications. For indoor use only. Refer to manufacturer's Installation Manual for details.

These devices do not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation).

XLf: 7320-0569:0137

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7320-0410:0195

Page 1 of 1

CATEGORY: 7320 -- SPEAKERS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HSSPK24WLPPR, HSSPK24WLPPW, HSSPK24WLPR, HSSPK24WLPW, HSSPK24-1575WLPPW, HSSPK24-1575WLPPR, HSSPK24-1575WLPR, and HSSPK24-1575WLPW speaker strobes. All models are intended for indoor use only and are wall mounted in a listed double-gang backbox. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING:

| | |
|------------|--|
| Speaker | 25 Vrms and 70.7 Vrms |
| Strobe | 24 VDC |
| Flash Rate | 60 flashes per minute |
| Candela | 15, 30, 60, 75 & 15/75, 110 for Model SSPK24WLP series 15/75 fixed candela for Model HSSPK24-1575WLP series |

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as speakers and speaker strobes for use with separately listed compatible fire alarm control units. Both models are suitable for the hearing impaired applications. For indoor use only. Refer to manufacturer's Installation Manual for details.

XLF: 7320-0569:0140

08-08-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7315-0410:0197

CATEGORY: 7315 -- POWER UNITS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models PE-6SN and PE-10SN Notification Appliance Circuit (NAC) Power Supply Units.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Input 120/240 VAC 50/60Hz
Output 24VDC @ 10A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For fire alarm use, the unit must provide battery backup suitable for at least 24 hours.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as power supply units for use with separately listed compatible fire alarm control units and notification appliances. Authority having jurisdiction should be consulted prior to installation. The unit can be programmed to generate the three-pulse temporal fire alarm evacuation signal (for total evacuation) in accordance with NFPA 72, 2010 edition.

XLF: 7315-0328:0189

10-31-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0199 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model TCF-142-M-ST media converter (serial to fiber optic) for use with fire alarm control unit.
Refer to listee's data sheet for additional product description and operational considerations.

RATING: Electrical: 12-42 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as fire alarm control unit accessory.

02-24-12 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7305-0410:0200 Page 1 of 1

CATEGORY: 7305 -- MISCELLANEOUS SIGNALING EQUIPMENT

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: "Type NM" Signaling Stations, Model PB-SA yellow station with a momentary octagonal button (push and release). Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a push button abort switch. For indoor use only.

NOTE: Units are not acceptable for use as fire alarm pull stations.

XLf: 7305-1416:0103

06-20-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0201 Page 1 of 2

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model RAI-LED smoke-automatic fire detector accessory. Designed specifically for use with listee's:

Photoelectric Smoke Detectors
Model ALG-V (CSFM Listing No. 7272-0410:149),
Model ALK-V (CSFM Listing No. 7272-0410:173),
Model ACA-V (CSFM Listing No. 7272-0410:182),

Ionization Smoke Detector
Model AIE-EA (CSFM Listing No. 7271-0410:148)

Heat Detector
Model ATG-EA (CSFM Listing No. 7270-0410:147)

Bases
Model HSB-NSA-6 (CSFM Listing No. 7300-0410:132)
Model YBN-NSA-6 (CSFM Listing No. 7300-0410:132)
Model ASB (CSFM Listing No. 7300-0410:161)
Model SCI-B4 (CSFM Listing No. 7300-0410:186)
Model SCI-B6 (CSFM Listing No. 7300-0410:186)

FACP
Model FireNET (CSFM Listing No. 7165-0410:159)
Model FireNET Plus (CSFM Listing No. 7165-0410:180)

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 7 mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a smoke-automatic fire detector accessory for use with the compatible detector

04-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

heads, bases and Fire Alarm Control Panels [FACP] listed above to provide a remote visual indication of an alarm condition. Refer to listee's Installation Instruction Manual for details.

NOTE:

The notification appliance is supplemental and is NOT intended as the primary evacuation signal appliance.

04-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7259-0410:0202 Page 1 of 1

CATEGORY: 7259 -- SMOKE DETECTOR-AIR SAMPLING TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models VPR-1, VPR-4, VPR-6, VPR-15 and VPR-1P air sampling, laser, aspirating smoke detector. The detectors are intended to detect an abnormal amount of smoke density in the area from which the detector is sampling and transmit this alarm signal to a fire alarm control panel. The fan draws in air from which a small amount of air is passed in to the detector chamber. The number of particles contained within the sampled air is measured using a laser. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, other applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction. Power supply must provide the required 24 hour standby power.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as an air sampling smoke detector system for use with separately listed compatible fire alarm control unit. Detectors must be used with a U.L. 1481 Listed power supply. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

XLf: 7259-1728:0100

08-05-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0410:0203

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model ATJ-EA Analog Addressable Combination 15°F Rate of Rise / 135-194°F Fixed Temperature Heat Detector for use with base Models HSB-NSA-6 or YBN-NSA-4. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 17.0 - 40.7 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical/temperature rating and UL label.

APPROVAL: Listed as heat detector for use with separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.

08-19-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-0410:0204 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models ALN-V and ACC-V analog addressable photoelectric smoke detectors for use with Models HSB-NSA-6 or YBN-NSA-4 bases.. Model ACC-V has a supplementary 135°F or 150°F heat detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 17.0 - 39.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical/temperature rating and UL label.

APPROVAL: Listed as an analog photoelectric smoke detector for use with listee's separately listed compatible fire alarm control units Models FireNet Plus (CSFM No. 7165-0410:0180) and FireNet 4127 (CSFM No. 7165-0410:0159) . Refer to listee's Installation Instruction Manual for details.

NOTE: The photoelectric type detectors are generally more effective at detecting slow, smoldering fires, which smolder for hours before bursting into flames. Sources of these fires may include cigarettes burning in couches or bedding. The ionization type detectors are generally more effective at detecting fast, flaming fires, which consume combustible materials rapidly and spread quickly. Sources of these fires may include paper burning in a waste container or a grease fire in the kitchen.

08-19-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7080-0410:0205

Page 1 of 1

CATEGORY: 7080 -- EXTINGUISHING SYSTEMS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models FNX-20S, *FNX-20T, FNX-40S, *FNX-40T, FNX-80S, *FNX-80T, FNX-100S, FNX-200S, FNX-500S, FNX-1200, *FNX-1200S, *FNX-1200T, *FNX-1200TS, FNX-2000, *FNX-2000S, *FNX-2000T, *FNX-2000TS, FNX-3000, *FNX-3000S, *FNX-3000T, *FNX-3000TS, *FNX-4200T, *FNX-4200TS, FNX-5700, *FNX-5700S, *FNX-5700T, *FNX-5700TS Pre-Engineered Aerosol Generating Fire Extinguishing System Units. Models *FNX-C125ABS, *FNX-C125AS, *FNX-C125RB, *FNX-C125RBR, FNX-MB-20S, *FNX-MB-4-8RBR, FNX-MB-4080S1/FNX-MB-4080S2, FNX-MB-125, FNX-MB-122030, *FNX-MB-122030/A, FNX-MB-57, *FNX-MB-57/C Bracket Assemblies. For Class A surface burning and Class B and C category hazards; not for use in hazardous (classified) locations. Temperature range -54 to 54°C. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, NFPA 2010 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as a Pre-Engineered Aerosol Generating Fire Extinguishing System.

XLF: 7080-2128:0100

Revision 01-21-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0206 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HCVR-3-R (115V), HCVR-3-R (230V), HCVR-3-C or HCVR-3-G (115 or 230V)
Releasing Panels.
Local, automatic, manual, waterflow and sprinkler supervisory service.

HCVR-3-ENC-BC f/b -R, -C or -G; Enclosure back box

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 115 Vac input.
230 Vac input.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

XLf: 7165-2298:0502

10/06/2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0207

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HCVR-ABE-R, HCVR-ABE-C, and HCVR-ABE-G Ancillary Board w/Enclosures.

Models S2027, S2028, and S2029 End-of-Line Devices.

Models HCVR-DS-R, HCVR-DS-C, and HCVR-DS-G Manual Extinguishant Disablement Switches.

Models HCVR-SDU-6S-R, HCVR-SDU-6F-R, HCVR-SDU-6SM-R, HCVR-SDU-6FM-R, HCVR-SDU-6S-C, HCVR-SDU-6S-G, HCVR-SDU-6F-C, HCVR-SDU-6F-G, HCVR-SDU-6SM-C, HCVR-SDU-6SM-G, HCVR-SDU-6FM-C, HCVR-6FM-G Status Units.

Models HCVR-SQA, HCVR-SQA-L Sequential Activator,

Models HCVR-AS-R, HCVR-AS-C, HCVR-AS-G Abort Switches.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with separately listed compatible fire alarm control units. Refer to manufacturer's Installation Manual for details.

XLF: 7120-2298:0501

10/06/2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-0410:0208

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models HEPA, HEPB, HEPG and HEPR extender plates with color strobes. Models HEPAS, HEPBS, HEPGS and HEPRS surface mounted extender plates with colored strobes. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as extender plates for wall mount indoor use with listee's separately listed speakers or speaker/strobes (CSFM No. 7320-0410:0194 or 7320-0410:0195) only. Refer to manufacturer's installation manual for details.

XLF: 7300-0569:0147

01-15-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0210

Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model ASBL low frequency 520 Hz addressable detector sounder base. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 17-41 Vdc

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a low frequency addressable detector base for use with listee's models ALG-V (CSFM No. 7272-0410:0149), ALK-V and ALK-V2 (CSFM No. 7272-0410:0173), ACA-V (CSFM No. 7272-0410:0182), AIE-EA (CSFM No. 7271-0410:0148), ATG-EA (CSFM No. 7270-0410:0147), ATJ-EA (CSFM No. 7270-0410:0203), ALN-V, ACC-V (CSFM No. 7272-0410:0204) and *Model ACD-V (CSFM Listing No. 7275-0410:0503) combination smoke/heat/CO detector heads. This unit can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.

*Revision 05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0211 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model EMS Graphix Remote Annunciator. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120 Vac

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as a remote annunciator for use with listee's separately listed FACP's. Refer to listee's Installation Instructions Manual for details.

03-23-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0410:0212 Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HHLF low frequency horn. The model may be followed by a letter indicating product color. Models HHSLF15, HHSLF110 and HHSLF177 low frequency horn/strobes. Horn/strobes models may be followed by -W or -R (white or red). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 Vdc/VFWR
Model HHSLF15 15 candela fixed
Model HHSLF110 110 candela fixed
Model HHSLF177 177 candela fixed

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a low frequency horn or low frequency horn/strobe when used with a separately listed electrically compatible fire alarm control unit. Horn/strobe models for wall mount only. All models are for indoor use only. These units can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to listee's Installation Instructions Manual for details.

XLf: 7135-0569:0148

04-04-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0410:0500

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models B6-24 and B10-24 fire bell. Model B6-24 has a 6 inch bell. Model B10-24 has a 10 inch bell. Suitable for outdoor use when used with Model BB-WP back box. Model BB-WP is a weather proof backbox. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or file number, model number, electrical ratings, date of manufacture, Identify Marking: "Fire Alarm Service" and UL label.

APPROVAL: Listed as audible devices for use with separately listed compatible fire alarm control units. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2013 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLf: 7135-1683:0100

01-26-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7260-0410:0501 Page 1 of 1

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Hochiki Model FireOptix 50MA Projected Beam Smoke Detector. Units consist of a controller, reflector, and a combined transmitter/receiver. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 14 -36 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as projected beam smoke detection systems for use with separately listed compatible fire alarm control units. Intended for mounting to vertical wall surfaces. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instruction Manual for details.

XLF: 7260-1508:0104

12-12-2016 dc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7275-0410:0503 Page 1 of 1

CATEGORY: 7275 -- COMBINATION SMOKE/CARBON MONOXIDE DETECTOR - PHOTOELECTRIC

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Hochiki Model ACD-V, combination smoke/heat/CO detector head. Model ACD-V can be programmed by the FACP to be either a smoke detector, heat detector, CO detector, or a combination photoelectric/smoke, heat, and CO detector. Fixed temperature 135°F or a 15°F Rate of Rise detector, or CO detector head.

RATING: 24-41 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number, electrical rating and UL label.

APPROVAL: Listed as a combination photoelectric smoke/heat/CO detector head for use with listee's separately listed compatible base and fire alarm control units. Also acceptable for duct application with air velocities from 0-4000 ft/min. Listed as heat type detector for use with listee's separately listed compatible base and fire alarm control units. Refer in Manufacturer's Installation Instruction Manual for details.

05-23-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7259-0410:0505 Page 1 of 1

CATEGORY: 7259 -- SMOKE DETECTOR-AIR SAMPLING TYPE

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Models VPR-SD1 and VPR-SD2 air sampling type smoke detectors. The Model VPR-SD1 employs a single air inlet port, a single air exhaust port, and a single chamber for mounting of a single smoke detector base and head. Two smoke detector bases and heads may be mounted inside of the chamber with one head serving as the primary sensing device and the other head serving as a backup. The Model VPR-SD2 employs two air inlet ports, a single, common, air exhaust port, and two, separate, chambers for mounting of two, separate, smoke detector bases and heads. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as air sampling type smoke detectors for open areas with air velocities between 0-4000 FPM and air duct application with a maximum velocity of 4000 FPM. Refer to listee's Installation Instruction Manual for details.

XLf: 7259-1728:0124

09-05-17 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0410:0506 Page 1 of 1

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model "L@titude" control unit, Model(s) LA followed by 1, 2, 3, 4, 7, 8, 9 or A, followed by 0, 1, 2 or 3, followed by 0, 1, 2 or 3, followed by 00 or H, I, J, or K, followed by 1 through 8, followed by 1, 4 or 6, followed by 0, 1, 3, 4, 5, 6 or 7, and may be optionally followed by 0 and 1 through 8. Analog addressable fire alarm control unit. Local, automatic, manual, auxiliary, remote station, central station, proprietary, waterflow and sprinkler supervisory service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

- S406; Power Supply
- S408; Power Supply
- S560; 16 Channel I/O Module
- S723; Network Module
- S758; Dual Loop Panel Module
- S769; System A Panel Module
- S770; System B Panel Module
- S771; Zone LED Module
- S787; Vision Network Annunciator
- S788; Media Gateway Panel Module

RATING: 120/240 VAC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm control units suitable for use with separately listed compatible initiating and indicating devices. These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2016 Edition. This control unit meets the requirements of UL-864, 10th Edition Standard. Refer to manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-2298:0500



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG, Program Coordinator**
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0410:0507

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model LFC00NC10, LFC00NC40, LFC00NC60, LFC10NC10, LFC10NC40, LFC10NC60, LFC20NC10, LFC20NC40, LFC20NC60, LFC30NC10, LFC30NC40, LFC30NC60 FireNET Vision Network Annunciator. Connects to the control panel(s) via the network interface.
*Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as annunciator panel for use with listee's separately listed compatible Model FireNET L@titude fire alarm control unit (CSFM Listing No. 7165-0410:0506). Refer to listee's Installation Instruction Manual for details.

XLf: 7120-2298:0503

10-1-2019 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0410:0508 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: Hochiki America Corporation 7051 Village Drive, Ste. 100, Buena Park, CA 90621-2268
Contact: Ravi Hem (714) 670-3248 Fax (714) 522-2268
Email: rhem@hochiki.com

DESIGN: Model HTSM sync module and may be followed by suffix W or R (white or red color). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC/VFWR

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a synchronization control module for indoor use with listee's listed strobes and horn/strobes. Refer to listee's Installation Instructions Manual for details.

XLf: 7300-0569:0149

03-20-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2022**

Listing Expires **June 30, 2023**

Authorized By: **VICTOR WONG**, Program Coordinator
Fire Engineering Division